



EMSL Analytical, Inc.
 107 Haddon Ave., Westmont, NJ 08108
 Phone: (856) 858-4800 Fax: (856) 858-4960 Email: westmontslab@EMSL.com

Attn: **Andrew Roark**
Assagai Analytical Laboratories, Inc.
4301 Masthead NE
P.O. Box 90430
Albuquerque, NM 87109

Fax: (505) 345-7259 Phone: (505) 345-8964
 Project: **TAOS ELEMENTARY SCHOOL**

Customer ID: AALI63
 Customer PO:
 Received: 07/28/09 10:30 AM
 EMSL Order: 040918937

EMSL Proj:
 Analysis Date: 7/28/2009

Sampling Date: 7/27/2009

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
 EPA 40 CFR Part 763 Appendix A to Subpart E**

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥ 0.5μ	< 5μ		≥ 5μ	(S/mm ²)
FS-09-270-0727-4 040918937-0001	INSIDE CONTAINMENT	1250.00	0.0650	0	None Detected			0.0047	<15.00	<0.0047
FS-09-270-0727-5 040918937-0002	INSIDE CONTAINMENT	1250.00	0.0650	0	None Detected			0.0047	<15.00	<0.0047
FS-09-270-0727-6 040918937-0003	INSIDE CONTAINMENT	1250.00	0.0650	0	None Detected			0.0047	<15.00	<0.0047
FS-09-270-0727-7 040918937-0004	INSIDE CONTAINMENT	1250.00	0.0650	0	None Detected			0.0047	<15.00	<0.0047
FS-09-270-0727-8 040918937-0005	INSIDE CONTAINMENT	1250.00	0.0650	0	None Detected			0.0047	<15.00	<0.0047

Analyst(s)

Will DiBella (5)

Stephen Siegel, C IHL, Laboratory Manager
 or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request. As per 40 CFR 763, the initial screening test may not be applied to samples with collected volumes of <1200 liters. The test results contained within this report meet the requirements of NELAP unless otherwise noted. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Westmont 107 Haddon Ave., Westmont NJ AIHA IHLAP 100194, NVLAP Lab Code 101048-0, NYS ELAP 10872